

T124-TR4500 Derince LubProd
Petrol Ofisi Caddesi
Kocaeli
41900
Turkey



Certificate of Analysis

Material	550074269	Date Manufactured	11 Nov 2025
Material Description	Shell Corena S3 R 68 1*20L JC	Date Tested	13 Nov 2025
Batch Number	12567459		

Test Description	Result	Unit	Method
Viscosity Kinematic 40°C	68,43	mm2/s	ASTM D445
Appearance	Clear and Bright	-	VISUAL
Density 15°C (by Densitymeter)	866,3	kg/m3	ASTM D4052
Pour Point	-30,0	CEL	ASTM D97

Date	17 Nov 2025
Certified by	Aslan Tasci
Preferred contact	+902623171815

We hereby confirm that the products supplied have been tested and conform to the quality requirements laid down by Shell International Petroleum Company Limited, London. This Quality System is certified against ISO 9001 and IATF 16949 standards.